

## Mobile Food Service Unit Inspection Consortium

# INSPECTION BULLETIN

A primary focus of Mobile Food Service Unit Inspection process is to minimize the risk of propane leaks, fires and explosions.

The Adopted Codes for Mobile Food Service Units require the propane fuel system to be tested and proven free of leaks on a annual basis.

The LP gas systems shall be certified for compliance with NFPA 58 by an approved company with expertise in the installation, inspection and maintenance of LP gas systems.

The test and inspection may be conducted by propane service company or a mechanical contractor who works with propane.

Please make sure that the person who does the inspection for you includes on the inspection report their legible name, date of inspection, vehicle information and that the inspection certifies the system was inspected for leaks and compliance with NFPA 58 and ANSI 21 standards.

This test is good for 1 year when there are no changes in the system other than replacing LP cylinders.